

June 11, 2002

Dear:

The Hancock County Water and Sewer District sent a letter stating that they believed the cause of their sewer system overflows was due to tidal waters infiltrating the individual grinder pump stations. The District informed us that they were going to replace gaskets on the grinder pump stations to alleviate this problem. We were then notified by email dated May 9, 2002, that the gaskets have been replaced on all the most "critical" systems and 3/4 have been replaced on the overall system.

Please let me know if you want copies of the letters and e-mail or additional documentation of the status. If I may ever be of assistance, please do not hesitate to contact me.

Very truly yours,

Michael Boyd
Policy & Planning Director

MTB:sed